

CENTRAL POWER RESEARCH INSTITUTE
(Member of STL)



TEST REPORT

Test Report Number	SC171821	Dated: 11 th October, 2017
Name & Address of the Customer	M/s. Mega Powerline (India), #2/3, SRS Market, Second Floor, VS Lane, Chickpet, Bengaluru – 560 053, Karnataka, India.	
Name & Address of the Manufacturer	M/s. Mega Powerline (India), #2/3, SRS Market, Second Floor, VS Lane, Chickpet, Bengaluru – 560 053, Karnataka, India.	
Particulars of sample tested	"MPL INDIA" Heat Shrinkable Indoor and outdoor terminations and one straight through joint mounted on 3x240 sq. mm, 6.35/11 kV Cable	
Condition of the sample on receipt	Good	
Type	---	
Description of test sample	"MPL INDIA" Heat Shrinkable Indoor and outdoor terminations and one straight through joint	
Serial number	---	
Number of samples tested	One	
Date (s) of test (s)	6 th & 9 th October, 2017	
CPRI sample code no(s).	CDDCAB17S0170	
Particulars of tests conducted	Thermal & Dynamic Short-circuit (Conductor)	
Test in accordance with Standard / specification	IS 13573 (Part 2): 2011 (Reaffirmed 2016) & Clause 11 & 12 of IS 13573 (Part 3): 2011 (Reaffirmed 2016)	
Sampling plan	Not applicable	
Customer's requirement	Nil	
Deviations if any	Nil	
Name of the witnessing persons		
Customer's representative	Mr. Hanuman Lal	
Other than customer's representatives	None	
Test subcontracted with address of the laboratory	None	
Documents constituting this report (in words)		
Number of sheets	Four	
Number of oscillograms	Three	
Number of graphs	Nil	
Number of photos	Three	
Number of test circuit diagrams	One	
Number of drawings	Nil	


(G. Venkatramanaiah)
Test Engineer




(Swaraj Kumar Das)
Joint Director